

Table 1
[Amended 05-03-15]

Minimum Separation Distances
Minimum Distance From

Structure or Topographic Features	Bottom or Sidewall of Subsurface Soil Absorption System Trenches Vault Privies (feet)	Septic Tanks (feet)	All Other Parts of the Subsurface Septic System (feet)
Slopes greater than 25%	Not permitted	N/A	N/A
Free flowing streams, natural lakes or impounded waters (measured from edge)	100	100	50
Intermittent stream	50	50	50
Drainageways (measured from low point)	50	50	N/A
Wells	100	100	50
Discernible edge of sinkholes and cave entrances	100	100	50
Springs at a lower elevation than the septic system	500	500	100
Springs at a higher elevation than the septic system	200	200	100
Utility Easement (edge of)			
Upslope	10	10	10
Downslope	25	25	10

NOTES: N/A = Not applicable.

D. Floodplain. New subsurface soil absorption (septic) systems shall not be permitted in the floodway portion of the Flood Plain District.

E. Replacement, repairs, and expansions of existing approved