

Appendix I Tables

Table I Minimum Safe Distances

Location of Wells

Sources of Contamination	Minimum Distance (feet)
Chemical storage tanks	100
Feedlots, hog lots, poultry houses	100
(Petroleum) storage tanks	100
Roads surface (public)	25
Septic tanks	100
Absorption field	100
Cesspools, pit privies, etc.	150
Intermittent streams	50
Other sewers	35
Perennial streams	100
Property lines	10
Foundation of buildings of solid masonry	50
Foundation of buildings of wood framing or exterior	50
Sinkholes and cave entrances	100
Termite treated foundations	100
Cemetery	100

NOTES:

In such installations where Class I wells are constructed, the distance between the potential sources of pollution may be reduced, provided that geological conditions indicate that such would be satisfactory and in accordance with the Division of Engineering, State Health Department, standards for location of public supplies in relation to potential sources of contamination.
