

**CLARKE COUNTY SANITARY AUTHORITY MEETING
SEPTEMBER 2, 2022
FINAL MINUTES**

PRESENT:

Mr. Roderick DeArment, Chairman
Mr. A. "Dan" Mackay-Smith, Vice-Chairman
Mr. Tom Bauhan, Treasurer, (via Teleconference)
Mr. C. Wayne Armbrust
Mr. Lee Coffelt (via Teleconference)
Mr. Bev McKay, Liaison for the Clarke County Board of Supervisors

OTHERS:

Mr. Daniel Boyd, Inboden Environmental Services
Mr. Mark Inboden, Inboden Environmental Services
Chris Boies, County Administrator
Mrs. Mary Meredith, Staff
Max Emma, Locke Store
Ruth Emma, Locke Store
Daniel Bell, Locke Store
Alan Johnston, P.E., FHC Engineering, PC
Additional members from Locke Store not introduced by name.

I. CALL TO ORDER

The meeting was called to order at 9:00am.

II. PUBLIC COMMENT

Mr. DeArment asked that Mr. Inboden follow up concerning the samples from the last meeting. Mr. Inboden reviewed the levels from four source points. The wet well was below at 94 mg/L. The wet well pipe, which would include everything upstream prior to entering the wet well, was 144 mg/L. The third test was the mop/vegetable sink at 169 mg/L and finally the sink with the grease trap is 116 mg/L. Mr. Emma did respond to state they are working with the plumber to slow the hydraulic flow from the sink with the grease trap installed.

Mr. Inboden commented that given the source points were above the 100 mg/L limit, it does cause concern that we would be in a similar situation again over time. He appreciates the effort, but we are not there yet.

Mr. Emma stated the plan is to route all sinks through the grease trap. They will also work to slow the flow of the hydraulic load when draining the sinks. They now have a contracted with First Choice Septic to scrape, clean, and pump. We have engaged with Pennoni to analyze our results without installing the large grease interceptor underground. Mr. Emma noted they are happy to keep testing

and paying for those results until we are within compliance. If compliance cannot be reached, then they will install a tank under the driveway.

The board continued discussions regarding testing regulations, and Mr. Inboden noted it is a standardized testing followed. Mrs. Emma requested that it would be helpful for future customers, to know what is required regarding maintaining a wet well. The board discussed this and Ms. Meredith stated she could review the Authority's standard detail as well as rules and regulations. If nothing is currently in the documents, wording can be added for their approval.

The motion stayed from last meeting was; that service be discontinued and that the five days' notice be given. If there is sufficient correction done and it appears to be functional, that the board consider changing the outcome. Mr. Armbrust noted showing the progress and the commitment the customers have shown, with the consent of the second on the motion; I request that we withdraw the motion.

Mr. DeArment suggested we have additional testing with more data to look at. That the customers can work with their engineers and we can review this at the next meeting. Mr. Bauhan asked if that would give Mr. Emma time to have something in writing from their engineer.

III. NEXT MEETING

The next is **Tuesday, September 20, 2022 at 9:00 a.m.**

IV. ADJOURNMENT

The meeting was adjourned.